

Client# C10023045A101

Date: 9.24.2019

Temp 88°

Client Name _____

Address _____

Square Footage 1955 Year Built 1987 # Bedrooms 3 # Bathrooms 4

Blower Door 3173 @-50 = 0.9 = Target 2855 @-50

Pressure Pans: Return 23.4 Living Room 3.9 3.7 Kitchen 3.2 4.1 Bedroom 4.4 3.6

Bedroom 3.2 3.8 Bathroom 3.9 Bedroom 4.5 4.1 Bathroom 5.1 Other 3.2 3.3

Heat Description: IRANE split system MFG: 2012 Fuel electric

Model # CAF2A0A305318AA Serial # 1220062L2V

Efficiency: 7.7 · 0.99 = 7.1 HSPF

Air Conditioning Description: 38' UNINSULATED TRUNK LINE - 10" - 18"

Model # 4TWP3030U1000AA Serial # 12133XF44F

Efficiency: 13 · 0.99 = 12.1 SEER

Water heater: US Craftmaster E40R10 45 110 PRV Pipe Needed? yes

Refrigerator: WHIRLPOOL model ET1PHKXPT09 MFG 2010 Fair Seal

Existing Insulation: Walls 3.5"

Attic Accesses needed - noise abate

Floor 2x10 -

Vapor Barrier Needed: N/A # Smoke Detectors Needed 7 # CO Needed 3

Bath Window y Fan CFM Ø Bath Window N Fan CFM Ø

Kitchen Window y Fan CFM 74-

Health & Safety Items Needed: Receptacle cover - dryer - down bath junction box - Varsenol

Dryer Vent Needed: yes

C1002304SA101

