

Client# C10033H SA101

Date: 8-30-2019

Temp 72°

Client Name _____

Address _____

Square Footage 1210 Year Built 1900 # Bedrooms 3 # Bathrooms 1

Blower Door 2204 @-50 Target 1210 @-50

Pressure Pans: Return 4.7 Living Room 2.8 Kitchen 3.9 Bedroom 29.7

Bedroom 3.3 Bathroom _____ Bedroom 2.4 Bathroom _____ Other _____

Heat Description: Carrier Packaged Heat Pump MFG: 2002 Fuel Electric

Model # 50 DX - 024 - 301AD Serial # 3802 G11387

Efficiency: $5.5 + (0.00875 \cdot 20) = 7.28$ HSPF $7.28 \cdot .99^{17} = 6.13$ HSPF

Air Conditioning Description: _____

Model # _____ MFG: _____ Serial # _____

Efficiency: $10.75 + (0.0750 \cdot 5) = 11.125 \cdot 0.99^{17} = 9.38$ SEER

Water heater: _____ PRV Pipe Needed? yes

Refrigerator: Whirlpool FJ20TKXDN01 MFG 90 fair seal

Existing Insulation: Walls R-11

Attic Creates an attic access - none ext - Batt, 3" fiberglass - ^{upgrade to 1.4"}

Floor Access needed

Vapor Barrier Needed: low crawl # Smoke Detectors Needed 4 # CO Needed 1

Bath Window y Fan CFM φ Bath Window _____ Fan CFM _____

Kitchen Window y Fan CFM φ

Health & Safety Items Needed: weatherproof ext outlet

Dryer Vent Needed: ext

Propane - Tank is empty

