

Client# C10018548A101

Date: 6-12-2020

Temp 73

Client Name _____

Address _____

Square Footage 24.36 804 Year Built 2001 # Bedrooms 3 # Bathrooms 2

Blower Door 2908 @-50 Target 804 @-50

Pressure Pans: Return 10.8 Living Room 6.4 1.2 Kitchen 10.3 Bedroom 8.5

Bedroom 12.4 Bathroom — Bedroom 7.6 Bathroom 8.2 Other 57.4/8

Heat Description: Goodman Heat pump - packaged MFG: 20060 Fuel: Electric Nat Gas Propane
Herzberg

Model # GPH1330H21A Serial # 0602445735

Efficiency: 7.7 0.99¹⁴ 6.68 HSPF

Air Conditioning Description: _____

Model # _____ MFG: _____ Serial # _____

Efficiency: 13 0.99¹⁴ 11.24 SEER

Water heater: _____ PRV Pipe Needed? _____

Refrigerator: _____

Existing Insulation: Walls 5.5"

Attic 0

Floor 3"

Vapor Barrier Needed: _____ # Smoke Detectors Needed 5 # CO Needed 1

Bath Window 4 Fan CFM 11 Bath Window 4 Fan CFM 13

Kitchen Window 4 Fan CFM 4

Health & Safety Items Needed: junction box needed @ wires in return

Dryer Vent Needed: _____

client does not use heat pump too expensive
weatherproof outlet cover needed -

C1001254SA101

