

Client# C10033505A101

Date: 12.12.2019

Temp 51°

Client Name _____

Address _____

Square Footage 808 Year Built 1925 # Bedrooms 2 # Bathrooms 1

Blower Door 3391 @-50 Target 1212 @-50

Pressure Pans: Return 22.4 Living Room 14.4 Kitchen 7.3 Bedroom 17.2

Bedroom 6.0 Bathroom 13.8 Bedroom _____ Bathroom _____ Other _____

Heat Description: OP RUUD Split System MFG: 1990 Fuel Electric

Model # UBHA-1451GSUWXL Serial # M2090 00499

Efficiency: _____

Air Conditioning Description: Data plate faded

Model # _____ MFG: _____ Serial # _____

Efficiency: 10.0 * 0.99²³ = 8.41 SEER2

Water heater: Rheem 81V520 PRV Pipe Needed? Y

Refrigerator: Whirlpool W8RVE6MWD03 MFG 2013 John Seal

Existing Insulation: Walls Ø

Attic 1.5" blown fiberglass - & chimney - Asphalt Vent - (gath)

Floor Ø

Vapor Barrier Needed: N/A # Smoke Detectors Needed 5 # CO Needed 3

Bath Window No Fan CFM Ø Bath Window _____ Fan CFM _____

Kitchen Window yes Fan CFM Ø

Health & Safety Items Needed: _____

Dryer Vent Needed: yes

Lead Saze - switch covers

Floor registers
porch light - hanging by wire

C1003356SA101

