

Client# C10037648A01

Date: 2-13-2020

Temp 51°

Client Name _____

Address _____

Square Footage 1088 Year Built 1998 # Bedrooms 3 # Bathrooms 2

Blower Door 2421 @-50 Target 1088 @-50

Pressure Pans: Return 2.5 Living Room 14.0 14.0 Kitchen 17.0 Bedroom 9.9

Bedroom 8.4 Bathroom 2.2 Bedroom 7.4 Bathroom _____ Other _____

~~X~~ BREAKER - POPS - FIRE RISK
Heat Description: forced Air-Nordyne MFG: 1998 Fuel: Electric Nat Gas _____ Propane _____

Model # F2EB-VIZHA Serial # EZE9803-08084

Efficiency: 41 kWh

Air Conditioning Description: Goodman

Model # A52140361BB MFG: 2012 Serial # 1212110304

Efficiency: _____

Water heater: FE2140HD04SV US Crytmaster PRV Pipe Needed? extend

Refrigerator: GLHSG9EE PW1 MFG: 05 Original SXS Fair Seal

Existing Insulation: Walls 3.5

Attic 2"

Floor 2" Bas-

Vapor Barrier Needed: _____ # Smoke Detectors Needed 4 # CO Needed 1


Bath Window g Fan CFM Ø Bath Window Ø Fan CFM 20

Kitchen Window g Fan CFM Ø

Health & Safety Items Needed: switch plate cover 1 outlet II

Dryer Vent Needed: yes

C1003764SA101



68'

