

Client# C10039875A101

Date: 9-28-2020

Temp 80°

Square Footage 840 Year Built 1983 # Bedrooms 3 # Bathrooms 1

Blower Door 1148 @-50 Target 840 @-50

Pressure Pans: Return 4.0 Living Room 5.4 Kitchen 3.7 Bedroom 3.0

Bedroom 4.3 Bathroom 0.8 Bedroom 2.0 Bathroom _____ Other _____

Heat Description: Coleman Jereed Air MFG: 1983 Fuel: Electric Nat Gas _____ Propane _____

Model # 3400-815 Serial # 108372159

Efficiency: 53 KBTU

Air Conditioning Description: Window unit - Room Working Condition: Air Temp 72° output

Model # WWK00CR91N MFG: 2018 Serial # _____

Efficiency: 6 KBTU 11 CFM

Water heater: Aphen XE40 M060T45U1 0.95 EF. PRV Pipe Needed? extend

Refrigerator: GE TA145CB Fair Seal - MFG 1984

Existing Insulation: Walls 2x8 R-11 8.12 porch

Attic 14" 3/4 @ ceiling - Bow - flat

Floor 3 1/2 R-11 Fair

Vapor Barrier Needed: _____ # Smoke Detectors Needed 4 # CO Needed 1

Bath Window yes Fan CFM ∅ Bath Window _____ Fan CFM _____

Kitchen Window yes Fan CFM ∅

Health & Safety Items Needed: junction box @ DWH

Dryer Vent Needed: exists

C1003987SA101

